



## DECLARATION OF PERFORMANCE : DoP No. 0053

Accordingly to Annex III of UE regulation No. 305/2011

## CE

1)Unique identification code of product-type : H05Z1Z1-F CPR CLASS Cca  $\,$  300/ 500 V<sub>AC</sub>  $\,$ 

2. Intended uses : supply of electricity or communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.

3. Manufacturer : SALCAVI S.p.A. Via dell'Industria,1 47867 Talamello (RN) - ITALY Tel. 0541 921101, Fax 0541 921494, email : <u>info@salcavi.com</u>

4. AVCP system : 1+

5. Authorized representative : not applicable

6) Harmonized standard : EN 50575:2014 + A1:2016

Notified product certification body : No. 0987 - LAPI Laboratorio Prevenzioni Incendi S.p.A

8. Class of performance :

reaction to fire test method classification method dangerous substances Cca-s1,d1,a1 EN 50399, IEC 60332-1-2, EN 50267-1, EN 50267-2-3 EN 13501-6:2014 NPD

All products listed at point 1 comply with all performances described at point 8. This declaration is issued in compliance with UE regulation No. 305/2011, on the sole resposibility of manufacturer that is stated at point 3.

Signed on behalf of manufacturer :

Giancarlo Farinelli Technical Manager Talamello 09/09/2019



DoP downloadable at following address : <u>www.salcavi.com</u>



