



DECLARATION OF PERFORMANCE: DoP No. 0053

Accordingly to Annex III of UE regulation No. 305/2011

- 1. Unique identification code of product-type : H05Z1Z1-F, 05Z1Z1-F CPR CLASS Cca 300/500 Vac
- 2. Intended uses : supply of electricity or communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.
- 3.)Manufacturer : SALCAVI S.p.A. Via dell'Industria,1 47867 Talamello (RN) ITALY Tel. 0541 921101, Fax 0541 921494, email: info@salcavi.com
- 4 AVCP system: 1+
- 5. Authorized representative : not applicable
- 6. Harmonized standard : EN 50575:2014 + A1:2016
- Notified product certification body : No. 0987 LAPI Laboratorio Prevenzioni Incendi S.p.A
- 8. Class of performance :

reaction to fire Cca-s1,d1,a1

EN 50399, IEC 60332-1-2, EN 50267-1, EN 50267-2-3 test method

classification method EN 13501-6:2014

NPD dangerous substances

All products listed at point 1 comply with all performances described at point 8. This declaration is issued in compliance with UE regulation No. 305/2011, on the sole resposibility of manufacturer that is stated at point 3.

Signed on behalf of manufacturer:

Giancarlo Farinelli Technical Manager

Talamello 09/09/2019



DoP downloadable at following address: www.salcavi.com



