

## DECLARATION OF PERFORMANCE : DoP No. 053/UK

Accordingly to Annex III of UE regulation No. 305/2011



1. Unique identification code of product-type : H05Z1Z1-F, 05Z1Z1-F CPR CLASS Cca 300/500 V<sub>AC</sub>
2. Intended uses : supply of electricity or communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke.
3. Manufacturer : SALCAVI S.p.A. Via dell'Industria,1 47867 Talamello (RN) - ITALY  
Tel. 0541 921101, Fax 0541 921494, email : [info@salcavi.com](mailto:info@salcavi.com)
4. AVCP system: 1+
5. Authorized representative : not applicable
6. Harmonized standard: EN 50575:2014 + A1:2016
7. Notified product certification body: N. 0987 - LAPI Laboratorio Prevenzioni Incendi S.p.A
8. Class of performance:

reaction to fire

**Cca-s1a, d1, a1**

test method

EN 50399, IEC 60332-1-2, EN 50267-1, EN 50267-2-3

classification method

EN 13501-6:2014


dangerous substances

NPD

All products listed at point 1 comply with all performances described at point 8. This declaration is issued in compliance with UE regulation No. 305/2011, on the sole responsibility of manufacturer that is stated at point 3.

Signed on behalf of manufacturer :

Giancarlo Farinelli  
Technical Manager  
Talamello 26/10/2022



DoP downloadable at following address : [www.salcavi.com](http://www.salcavi.com)